


TYPICAL WIRING DIAGRAM

## NOTES:

- 1. ALL UNITS ARE cUL LISTED & DESIGNED ACCORDANCE WITH INDUSTRY STANDARDS.
- 2. TRANSFORMERS ARE DRY—TYPE, CLASS
  AA, ENCAPSULATED NEMA 3R ENCLOSED
  FOR INDOOR / OUTDOOR USE.
- 3. TRANSFORMERS ARE WALL / MACHINE MOUNTABLE VIA THE ATTACHED BRACKETS.
- 4. TRANSFORMERS ARE CONSTRUCTED BASED UPON A 40°C AMBIENT ENVIRONMENT.
- UPON A 40°C AMBIENT ENVIRONMENT.
  5. MAINTAIN 1" CLEARANCE FROM ALL LIVE PARTS.
- 6. PAINT COLOR IS ANSI# 61.



TERMINAL VIEW

**DRAWINGS** 

## APPROXIMATE DIMENSIONS ( INCHES )

KVA	Α	В	С	D	E	F	HARDWARE	MTG SLOTS	ENCLOSURE	lbs.	WEATHER' SHIELD	TERMINAL TYPE
8.5	13.25	6.25	7.75	12.50	4.50		1/4-20	0.312" x 0.812	FPT-1500	45	N/A	LEADs

X APPROVAL RECORD \* ELECTROSTATIC SHIELD GROUNDED TO TRANSFORMER CASE AT FACTORY ( IF APPLICABLE ) □ OTHER INPUT CUST. 277 XXXXXXX VOLTAGE OUPUT JOB 230 VOLTAGE TEMPERATURE 115 **CATALOG** RISE IN C WINDINGS & **COPPER ALUMINUM** NOTE **XXXXXXX** TERMINALS **FREQUENCY** ENG. LOG. BY TITLE 1-PHASE, 600 VOLT CLASS 60 HERTZ **AUTO** INPUT DATE NONE DRY TYPE TRANSFORMER TAPS MFG. LOG. DWG. NO. **REV** PTN491-A8.5K DWG. FILE DATE: