



## NOTES:

- ALL UNITS ARE CUL LISTED & DESIGNED ACCORDANCE WITH INDUSTRY STANDARDS.
- 2. TRANSFORMERS ARE DRY-TYPE, CLASS
  AA, HOUSED WITHIN NEMA 12 ENCLOSURE
  FOR INDOOR / DUSTPROOF USE.
- 3. DISCONNECT HAS DUAL BRACKET SYSTEM FOR BACK OR BOTTOM MOUNTING.
- 4. TRANSFORMERS ARE CONSTRUCTED BASED UPON A 40°C AMBIENT ENVIRONMENT.
- 5. MAINTAIN 1" CLEARANCE FROM ALL LIVE PARTS.
- 6. PAINT COLOR IS RAL# 7042.





DRAWINGS

▼ APPROVAL

## APPROXIMATE DIMENSIONS ( INCHES )

KVA	Α	В	С	D	E	F	HARDWARE	MTG SLOTS	ENCLOSURE	IDS.	WEATHER SHIELD	TERMINAL TYPE
3.0	12.00	17.00	10.00	4.00	15.88	6.00	1/4-20	0.312" x 0.312"	PLDN-MOD-UM	70	N/A	TBs

RECORD \* ELECTROSTATIC SHIELD GROUNDED TO TRANSFORMER CASE AT FACTORY ( IF APPLICABLE ) □ OTHER PRIMARY CUST. 480 XXXXXXX VOLTAGE SECONDARY JOB 120 VOLTAGE TEMPERATURE 115 200kA SCCR FUSIBLE DISCONNECT SWITCH PRIMARY: RISE IN C WINDINGS & **COPPER ALUMINUM** SECONDARY: RED POWER-ON LIGHT TERMINALS FREQUENCY BY ENG. LOG. TITLE 1-PHASE, 600 VOLT CLASS 60 HERTZ LIGHTING DISCONNECT PRIMARY DATE DRY TYPE TRANSFORMER NONE TAPS MFG. LOG. DWG. NO. REV PLDN-3000-NR-A DWG. FILE DATE: