


## NOTES:

- 1. ALL UNITS ARE CUL LISTED & DESIGNED ACCORDANCE WITH INDUSTRY STANDARDS.
- 2. TRANSFORMERS ARE DRY-TYPE, CLASS AA, ENCAPSULATED NEMA 3R ENCLOSED FOR INDOOR / OUTDOOR USE.
- 3. TRANSFORMERS ARE WALL / MACHINE MOUNTABLE VIA THE ATTACHED BRACKETS.
- 4. TRANSFORMERS ARE CONSTRUCTED BASED UPON A 40°C AMBIENT ENVIRONMENT.
- 5. MAINTAIN 1" CLEARANCE FROM ALL LIVE PARTS.
- 6. PAINT COLOR IS ANSI# 61.



## APPROXIMATE DIMENSIONS ( INCHES )

KVA	А	В	С	D	E	F	HARDWARE	MTG SLOTS	ENCLOSURE	lbs.	WEATHER' SHIELD	TERMINAL TYPE
1.0	13.25	6.25	7.75	12.50	4.50		1/4-20	0.312" x 0.812"	FPT-212	45	N/A	LEADs

\* ELECTROSTATIC SHIELD GROUNDED TO TRANSFORMER CASE AT FACTORY ( IF APPLICABLE )

**DRAWINGS** ▼ APPROVAL RECORD

					( , , , ,	OTHER
PRIMARY VOLTAGE	277 – 480	CUST.	xxxxxxx			
SECONDARY VOLTAGE	208 - 277	JOB				
TEMPERATURE RISE IN *C	115	CATALOG				
WINDINGS & TERMINALS	LALUMINUM COPPER	NOTE	XXXXXXX			
FREQUENCY IN HERTZ	60	BY	ENG. LOG.	TITLE	1-PHASE, 600 VOLT CLASS ISOLATION	
PRIMARY TAPS	NONE	DATE				
	A ÆDTDON.	REV	MFG. LOG.	DWG. NO.		
PO	AAFKHKU.	DATE:	DWG. FILE		N3F530L1000	