


## NOTES:

- ALL UNITS ARE cUL LISTED & DESIGNED ACCORDANCE WITH INDUSTRY STANDARDS.
- 2. TRANSFORMERS ARE DRY—TYPE, CLASS AA, ENCAPSULATED NEMA 3R ENCLOSED FOR INDOOR / OUTDOOR USE.
- 3. TRANSFORMERS ARE WALL / MACHINE MOUNTABLE VIA THE ATTACHED BRACKETS.
- 4. TRANSFORMERS ARE CONSTRUCTED BASED UPON A 40°C AMBIENT ENVIRONMENT.
- 5. MAINTAIN 1" CLEARANCE FROM ALL LIVE PARTS.
- 6. PAINT COLOR IS ANSI# 61.



## APPROXIMATE DIMENSIONS ( INCHES )

KVA	А	В	С	D	E	F	HARDWARE	MTG SLOTS	ENCLOSURE	WEIGHT	WEATHER' SHIELD	TERMINAL TYPE
3.0	15.25	12.38	9.00	8.50	11.25	1.50	3/8-16	0.437" x 0.750"	N10-N3R	105	N/A	LEADs

st ELECTROSTATIC SHIELD GROUNDED TO TRANSFORMER CASE AT FACTORY ( IF APPLICABLE )

DRAWINGS

APPROVAL

RECORD

					,	OTHER
PRIMARY VOLTAGE	277 – 480	CUST.	xxxxxxx			
SECONDARY VOLTAGE	208 - 277	JOB				
TEMPERATURE RISE IN °C	115	CATALOG				_
WINDINGS & TERMINALS	ALUMINUM KOPPER	NOTE	XXXXXXX			
FREQUENCY IN HERTZ	60	BY	ENG. LOG.	TITLE	1-PHASE, 600 VOLT CLASS ISOLATION	
PRIMARY TAPS	NONE	DATE				
		REV	MFG. LOG.	DWG. NO.		
1 <del>0</del>	VVEKIKAN.	DATE:	DWG. FILE		N3F530L3000	