




NOTES:

- 1. ALL UNITS ARE CUL LISTED & DESIGNED ACCORDANCE WITH INDUSTRY STANDARDS.
- 2. TRANSFORMERS ARE DRY-TYPE, CLASS AA, ENCAPSULATED NEMA 1 ENCLOSED FOR INDOOR USE.
- 3. TRANSFORMERS ARE WALL/MACHINE MOUNTABLE VIA SIDE BRACKETS.
- 4. TRANSFORMERS ARE CONSTRUCTED BASED
- UPON A 40°C AMBIENT ENVIRONMENT.
 5. MAINTAIN 1" CLEARANCE FROM ALL LIVE PARTS.
- 6. PAINT COLOR IS RAL# 7042.







TERMINAL VIEW

APPROXIMATE DIMENSIONS (INCHES)

KVA	А	В	С	D	E	F	HARDWARE	MTG SLOTS	ENCLOSURE	WEIGHT	WEATHER' SHIELD	TERMINAL TYPE
3.0	15.25	12.38	9.00	8.50	11.25		3/8-16	0.437" x 0.750"	N10	125	N/A	TBs

* ELECTROSTATIC SHIELD GROUNDED TO TRANSFORMER CASE AT FACTORY (IF APPLICABLE)

DRAWINGS

X APPROVAL

☐ RECORD

☐ OTHER

						, , , , , , , , , , , , , , , , , , ,	COLHER		
PRIMARY VOLTAGE	240 [DELTA	CUST.	XXXXXXX			•		
SECONDARY VOLTAGE	400Y,	/231	JOB						
TEMPERATURE RISE IN °C	11	5	CATALOG						
WINDINGS & TERMINALS	□ ALUMINUM	X COPPER	NOTE	XXXXXXX					
FREQUENCY HERTZ	60 228, 252		BY	ENG. LOG.	TITLE	3-PHASE, 600 VOLT CLASS ISOLATION			
PRIMARY TAPS			DATE						
. DO	A ŒDT	DOLL.	REV	MFG. LOG.	DWG. NO.	3FF716FST3			
70	VVEITI	DATE:	DWG. FILE						