


NOTES:

- 1. ALL UNITS ARE CUL LISTED AND DESIGNED ACCORDANCE WITH INDUSTRY STANDARDS.
- 2. TRANSFORMERS ARE DRY-TYPE, CLASS
 AA, ENCAPSULATED NEMA 3R ENCLOSED
 FOR INDOOR / OUTDOOR USE.
- 3. TRANSFORMERS ARE WALL / MACHINE MOUNTABLE VIA THE ATTACHED BRACKETS.
- 4. TRANSFORMERS ARE CONSTRUCTED BASED UPON A 40°C AMBIENT ENVIRONMENT.

DRAWINGS

▼ APPROVAL

- 5. MAINTAIN 1" CLEARANCE FROM ALL LIVE PARTS.
- 6. PAINT COLOR IS ANSI# 61.



APPROXIMATE DIMENSIONS (INCHES)

KVA	А	В	С	D	E	F	G	HARDWARE	(4) MTG SLOTS	BOX	lbs.	WEATHER' SHIELD	TERMINAL TYPE
3.0*	12.06	12.12	8.38	6.50	10.00			3/8-16	0.375" x 1.75"	FPT-3K	95	N/A	LEADs

RECORD * ELECTROSTATIC SHIELD GROUNDED TO TRANSFORMER CASE AT FACTORY (IF APPLICABLE) □ OTHER PRIMARY CUST. 480 DELTA XXXXXXXXX VOLTAGE SECONDARY JOB 240 DELTA VOLTAGE TEMPERATURE 115 **CATALOG** RISE IN °C WINDINGS & **COPPER ALUMINUM** NOTE **ELECTROSTATICALLY SHIELDED** TERMINALS **FREQUENCY** BY ENG. LOG. TITLE 3-PHASE, 600 VOLT CLASS 60 IN HERTZ **ISOLATION** DATE PRIMARY 432, 456 DRY TYPE TRANSFORMER TAPS MFG. LOG. DWG. NO. REV 3PB41-3K DWG. FILE DATE: