



## NOTES:

- 1. ALL UNITS ARE CUL LISTED & DESIGNED ACCORDANCE WITH INDUSTRY STANDARDS.
- 2. TRANSFORMERS ARE DRY-TYPE, CLASS AA, ENCAPSULATED NEMA 1 ENCLOSED FOR INDOOR USE.
- 3. TRANSFORMERS ARE WALL/MACHINE MOUNTABLE VIA SIDE BRACKETS.
- 4. TRANSFORMERS ARE CONSTRUCTED BASED
- UPON A 40°C AMBIENT ENVIRONMENT.
  5. MAINTAIN 1" CLEARANCE FROM ALL LIVE PARTS.
- 6. PAINT COLOR IS RAL# 7042.





TERMINAL VIEW

## APPROXIMATE DIMENSIONS ( INCHES )

					`							
KVA	А	В	С	D	E	F	HARDWARE	MTG SLOTS	ENCLOSURE	WEIGHT	WEATHER' SHIELD	TERMINAL TYPE
3.0	15.25	12.38	9.00	8.50	11.25		3/8-16	0.437" x 0.750"	N10	125	N/A	TBs

\* ELECTROSTATIC SHIELD GROUNDED TO TRANSFORMER CASE AT FACTORY ( IF APPLICABLE )

DRAWINGS

X APPROVAL

□ RECORD

□ OTHER

			,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,	,	5/10E /11 11	, i.e., e.g., i.e., i.e.	COLHER		
PRIMARY VOLTAGE	600 [	DELTA	CUST.	xxxxxxx			•		
SECONDARY VOLTAGE	415Y,	/240	JOB						
TEMPERATURE RISE IN °C	11	5	CATALOG						
WINDINGS & TERMINALS	□ ALUMINUM	COPPER	NOTE	xxxxxxx					
FREQUENCY HERTZ	60 570, 630		BY	ENG. LOG.	TITLE	3-PHASE, 600 VOLT CLASS ISOLATION			
PRIMARY TAPS			DATE						
. DO	ΛŒDΙ	DOM.	REV	MFG. LOG.	DWG. NO.	3EF446FST3			
70	VVEITI	DATE:	DWG. FILE						