


NOTES:

- 1. ALL UNITS ARE CUL LISTED & DESIGNED ACCORDANCE WITH INDUSTRY STANDARDS.
- 2. TRANSFORMERS ARE DRY-TYPE, CLASS AA, ENCAPSULATED NEMA 1 ENCLOSED FOR INDOOR USE.
- 3. TRANSFORMERS ARE WALL / MACHINE MOUNTABLE VIA THE ATTACHED BRACKETS.
- 4. TRANSFORMERS ARE CONSTRUCTED BASED UPON A 40°C AMBIENT ENVIRONMENT. 5. MAINTAIN 1" CLEARANCE FROM ALL
- LIVE PARTS.
- 6. PAINT COLOR IS RAL# 7042.



APPROXIMATE	DIMENSIONS ((INCHES)
-------------	--------------	----------	---

KVA	Α	В	С	D	E	F	HARDWARE	MTG SLOTS	ENCLOSURE	lbs.	WEATHER SHIELD	TERMINAL TYPE
6.0	16.25	19.12	8.50	8.50	17.75		3/8-16	0.437" x 0.750"	3N10	195	N/A	TBs

* ELECTROSTATIC SHIELD GROUNDED TO TRANSFORMER CASE AT FACTORY (IF APPLICABLE)

DRAWINGS X APPROVAL RECORD

						OTHER
PRIMARY VOLTAGE	208-240-480 DELTA	CUST.	xxxxxxx			
SECONDARY VOLTAGE	400Y/231	JOB				
TEMPERATURE RISE IN °C	115	CATALOG				
WINDINGS & TERMINALS	LALUMINUM X COPPER	NOTE	XXXXXX			
FREQUENCY IN HERTZ	60	BY	ENG. LOG.	TITLE	3-PHASE, 600 VOLT CLASS ISOLATION	
PRIMARY TAPS	NONE	DATE		DRY TYPE TRANSFORMER		
-POVVERTRAN-		REV	MFG. LOG.	DWG. NO. 3EF863FST6		
		DATE:	DWG. FILE			