




NOTES:

- 1. ALL UNITS ARE DESIGNED IN ACCORDANCE WITH INDUSTRY STANDARDS.
- 2. TRANSFORMERS ARE DRY-TYPE, CLASS AA, ENCAPSULATED NEMA 1 ENCLOSED FOR INDOOR USE.
- 3. TRANSFORMERS ARE WALL / MACHINE MOUNTABLE VIA THE ATTACHED BRACKETS.
- 4. TRANSFORMERS ARE CONSTRUCTED BASED UPON A 40°C AMBIENT ENVIRONMENT
- UPON A 40°C AMBIENT ENVIRONMENT.
 5. MAINTAIN 1" CLEARANCE FROM ALL
 LIVE PARTS.
- 6. PAINT COLOR IS RAL# 7042.







TERMINAL VIEW

APPROXIMATE DIMENSIONS (INCHES)

KVA	Α	В	С	D	E	F	HARDWARE	MTG SLOTS	ENCLOSURE	lbs.	WEATHER' SHIELD	TERMINAL TYPE
6.0	15.25	12.38	9.00	8.50	11.25		3/8-16	0.437" x 0.750"	N10	145	N/A	TBs

* ELECTROSTATIC SHIELD GROUNDED TO TRANSFORMER CASE AT FACTORY (IF APPLICABLE)

DRAWINGS

X APPROVAL

☐ RECORD

☐ OTHER

	ELECTROSTATIO STILLED	ONOONDED TO TH	ANDI ONMEN	OASE AT TA	ACTORY (II ALLEGABLE)	□ OTHER	
PRIMARY VOLTAGE	480 DELTA	CUST.	xxxxxxx			•	
SECONDARY VOLTAGE	480Y/277	JOB					
TEMPERATURE RISE IN °C	115	CATALOG					
WINDINGS & TERMINALS	LALUMINUM X COPPER	NOTE	XXXXXXX				
FREQUENCY HERTZ	60	BY	ENG. LOG.	TITLE	3-PHASE, 600 VOLT CLASS ISOLATION		
PRIMARY TAPS	456, 504	DATE		DRY TYPE TRANSFORMER			
. DO	л стртром.	REV	MFG. LOG.	DWG. NO.	7554545070		
70	O O ENTRAIN	DATE:	DWG. FILE		3EF454FST6		