



## **NOTES:**

- 1. ALL UNITS ARE CUL LISTED AND DESIGNED ACCORDANCE WITH INDUSTRY STANDARDS.
- 2. TRANSFORMERS ARE DRY-TYPE, CLASS AA, VENTILATED NEMA 1 ENCLOSED FOR INDOOR USE.
- 3. TRANSFORMERS ARE FLOOR MOUNTED.
- 4. TRANSFORMERS ARE CONSTRUCTED BASED UPON A 40°C AMBIENT ENVIRONMENT.
- 5. MAINTAIN 1" CLEARANCE FROM ALL LIVE PARTS.
- 6. PAINT COLOR IS ANSI #61.





FRONT VIEW

SIDE VIEW

TERMINAL DETAILS

## APPROXIMATE DIMENSIONS ( INCHES )

KVA	А	В	С	D	E	F	G	Н	J	К	L	BOX	lbs.	WEATHER SHIELD	TERMINAL TYPE
440.0	60.50	50.38	34.25	42.63	32.00	12.50	10.25	3.75	40.00	28.00		2-P	2085	N/A	BUSBAR

\* ELECTROSTATIC SHIELD GROUNDED TO TRANSFORMER CASE AT FACTORY ( IF APPLICABLE )

**DRAWINGS X** APPROVAL RECORD ☐ OTHER

PRIMARY VOLTAGE	230 DE	LTA	CUST.	xxxxxxxx	X					
SECONDARY VOLTAGE	460Y/2	266	JOB							
TEMPERATURE RISE IN *C	150		CATALOG							
WINDINGS & TERMINALS	X ALUMINUM	COPPER	NOTE	XXXXXXX						
FREQUENCY IN HERTZ	60		BY	ENG. LOG.	TITLE					
PRIMARY TAPS	218, 2	242	DATE	DRIVE ISOLATION DRY TYPE TRANSFORMER						
DO	A CEDI	REV	MFG. LOG.	DWG. NO.	<del> </del>					
770	VVEITI	DATE:	DWG. FILE	1	T					