



NOTES:

- 1. ALL UNITS ARE CUL LISTED AND DESIGNED ACCORDANCE WITH INDUSTRY STANDARDS.
- TRANSFORMERS ARE DRY—TYPE, CLASS
 AA, VENTILATED NEMA 1 ENCLOSED
 FOR INDOOR USE.
- 3. TRANSFORMERS ARE FLOOR MOUNTED.
- 4. TRANSFORMERS ARE CONSTRUCTED BASED UPON A 40°C AMBIENT ENVIRONMENT.
- 5. MAINTAIN 1" CLEARANCE FROM ALL LIVE PARTS.
- 6. PAINT COLOR IS ANSI #61.





TERMINAL DETAILS

APPROXIMATE DIMENSIONS (INCHES)

KVA	А	В	С	D	E	F	G	H	7	K	L	вох	lbs.	WEATHER SHIELD	TERMINAL TYPE
550.0	72.00	53.38	44.38	49.00	42.00	12.63	16.00	4.25	37.00	37.00		2-P	2750	N/A	BUSBAR

* ELECTROSTATIC SHIELD GROUNDED TO TRANSFORMER CASE AT FACTORY (IF APPLICABLE)

DRAWINGS

APPROVAL

RECORD

OTHER

PRIMARY VOLTAGE	230 DEI	LTA	CUST.	xxxxxxx	X					
SECONDARY VOLTAGE	460Y/2	.66	JOB							
TEMPERATURE RISE IN °C	150		CATALOG							
WINDINGS & TERMINALS	X ALUMINUM	COPPER	NOTE	XXXXXXX						
FREQUENCY IN HERTZ	60		BY	ENG. LOG.	TITLE	3-PHASE, 600 VOLT CLASS				
PRIMARY TAPS	218, 242		DATE			DRIVE ISOLATION DRY TYPE TRANSFORMER				
DO	A ŒDI	REV	MFG. LOG.	DWG. NO.	7DTNOFF	· · · · · · · · · · · · · · · · · · ·				
יטיו	O O EITI	DATE:	DWG. FILE		3PTN255-550K-DI					