


NOTES:

- 1. ALL UNITS ARE CUL LISTED AND DESIGNED ACCORDANCE WITH INDUSTRY STANDARDS.
- 2. TRANSFORMERS ARE DRY-TYPE, CLASS AA, ENCAPSULATED NEMA 1 ENCLOSED FOR INDOOR USE.
- 3. TRANSFORMERS ARE WALL / MACHINE MOUNTABLE VIA THE ATTACHED BRACKETS.
- 4. TRANSFORMERS ARE CONSTRUCTED BASED UPON A 40°C AMBIENT ENVIRONMENT.
 5. MAINTAIN 1" CLEARANCE FROM ALL
- LIVE PARTS.
- 6. PAINT COLOR IS RAL# 7042.



APPROXIMATE	DIMENSIONS	(INCHES)	

KVA	А	В	С	D	E	F	HARDWARE	MTG SLOTS	ENCLOSURE	lbs.	WEATHER' SHIELD	TERMINAL TYPE
9.0	16.25	19.12	8.50	8.50	17.75		3/8-16	0.437" x 0.750"	3N10	195	N/A	TBs

* ELECTROSTATIC SHIELD GROUNDED TO TRANSFORMER CASE AT FACTORY (IF APPLICABLE)

DRAWINGS X APPROVAL \square RECORD

							□ OTHER		
PRIMARY VOLTAGE	208 DI	ELTA	CUST.	xxxxxxx					
SECONDARY VOLTAGE	208Y/	120	JOB						
TEMPERATURE RISE IN °C	115	5	CATALOG						
WINDINGS & TERMINALS	L ALUMINUM	COPPER	NOTE	XXXXXX					
FREQUENCY IN HERTZ	60	1	BY	ENG. LOG.	TITLE	3-PHASE, 600 VOLT CLASS ISOLATION			
PRIMARY TAPS	198, 2	218	DATE			DRY TYPE TRANSFORMER			
DOD A CERTRON			REV	MFG. LOG.	DWG. NO.				
10	UVENI	DATE:	DWG. FILE		3EF043FST9				