


TYPICAL WIRING DIAGRAM

## **NOTES:**

- 1. ALL UNITS ARE cUL LISTED & DESIGNED ACCORDANCE WITH INDUSTRY STANDARDS.
- 2. TRANSFORMERS ARE DRY-TYPE, CLASS AA, ENCAPSULATED NEMA 3R ENCLOSED FOR INDOOR / OUTDOOR USE.
- 3. TRANSFORMERS ARE WALL / MACHINE MOUNTABLE VIA THE ATTACHED BRACKETS.
- 4. TRANSFORMERS ARE CONSTRUCTED BASED
- UPON A 40°C AMBIENT ENVIRONMENT. 5. MAINTAIN 1" CLEARANCE FROM ALL LIVE PARTS.
- 6. PAINT COLOR IS ANSI# 61.



TERMINAL VIEW

**DRAWINGS** 

## APPROXIMATE DIMENSIONS ( INCHES )

KVA	Α	В	С	D	Е	F	HARDWARE	MTG SLOTS	ENCLOSURE	lbs.	WEATHER' SHIELD	TERMINAL TYPE
1.7	11.25	5.25	6.50	10.50	3.50		1/4-20	0.312" x 0.812"	FPT-500	30	N/A	LEADs

X APPROVAL RECORD \* ELECTROSTATIC SHIELD GROUNDED TO TRANSFORMER CASE AT FACTORY ( IF APPLICABLE ) □ OTHER INPUT CUST. 277 XXXXXXX VOLTAGE OUPUT JOB 208 VOLTAGE TEMPERATURE 115 **CATALOG** RISE IN C WINDINGS & **COPPER ALUMINUM** NOTE **XXXXXXX** TERMINALS **FREQUENCY** ENG. LOG. BY TITLE 1-PHASE, 600 VOLT CLASS 60 HERTZ **AUTO** INPUT DATE NONE DRY TYPE TRANSFORMER TAPS MFG. LOG. DWG. NO. **REV** PTN951-A1.7K DWG. FILE

DATE: