


NOTES:

- ALL UNITS ARE CUL LISTED & DESIGNED ACCORDANCE WITH INDUSTRY STANDARDS.
- 2. TRANSFORMERS ARE DRY-TYPE, CLASS AA, HOUSED WITHIN NEMA 1 ENCLOSURE FOR INDOOR / CONTROL-PANEL USE.
- 3. DISCONNECT HAS DUAL BRACKET SYSTEM FOR BACK OR BOTTOM MOUNTING.
- 4. TRANSFORMERS ARE CONSTRUCTED BASED UPON A 40°C AMBIENT ENVIRONMENT.
- 5. MAINTAIN 1" CLEARANCE FROM ALL LIVE PARTS.
- 6. PAINT COLOR IS RAL# 7042.



APPROXIMATE DIMENSIONS (INCHES)

KVA	Α	В	C	D	E	F	HARDWARE	MTG SLOTS	ENCLOSURE	lbs.	WEATHER' SHIELD	TERMINAL TYPE
3.0	11.00	16.25	10.00	4.00	15.00	6.00	1/4-20	0.312" x 0.312"	PLD-MOD-UM	70	N/A	TBs

DRAWINGS X APPROVAL RECORD * ELECTROSTATIC SHIELD GROUNDED TO TRANSFORMER CASE AT FACTORY (IF APPLICABLE) □ OTHER PRIMARY CUST. 480 **XXXXXXX** VOLTAGE SECONDARY JOB 120 VOLTAGE TEMPERATURE 115 200kA SCCR FUSIBLE DISCONNECT SWITCH PRIMARY: RISE IN C WINDINGS & **COPPER ALUMINUM** SECONDARY: 15A DUPLEX RECEPTACLE and RED POWER-ON LIGHT TERMINALS FREQUENCY BY ENG. LOG. TITLE 1-PHASE, 600 VOLT CLASS 60 HERTZ LIGHTING DISCONNECT PRIMARY DATE DRY TYPE TRANSFORMER NONE TAPS MFG. LOG. DWG. NO. REV PLD-3000-A DWG. FILE DATE: