


NOTES:

- 1. ALL UNITS ARE CUL LISTED & DESIGNED ACCORDANCE WITH INDUSTRY STANDARDS.
- 2. TRANSFORMERS ARE DRY-TYPE, CLASS AA, ENCAPSULATED NEMA 1 ENCLOSED FOR INDOOR USE.
- 3. TRANSFORMERS ARE WALL / MACHINE MOUNTABLE VIA THE ATTACHED BRACKETS.
- 4. TRANSFORMERS ARE CONSTRUCTED BASED UPON A 40°C AMBIENT ENVIRONMENT.
 5. MAINTAIN 1" CLEARANCE FROM ALL
- LIVE PARTS.
- 6. PAINT COLOR IS RAL# 7042.



	APPROXIMATE	DIMENSIONS	(INCHES)	
--	-------------	------------	---	--------	---	--

KVA	Α	В	С	D	E	F	HARDWARE	MTG SLOTS	ENCLOSURE	lbs.	WEATHER' SHIELD	TERMINAL TYPE
15.0	16.25	19.12	10.50	8.50	17.75		3/8-16	0.437" × 0.750"	3N15	300	N/A	TBs

* ELECTROSTATIC SHIELD GROUNDED TO TRANSFORMER CASE AT FACTORY (IF APPLICABLE)

DRAWINGS X APPROVAL \square RECORD

						□ OTHER	
PRIMARY VOLTAGE	400 DELTA	CUST.	×××××××			,	
SECONDARY VOLTAGE	480Y/277	JOB					
TEMPERATURE RISE IN °C	115	CATALOG					
WINDINGS & TERMINALS	LALUMINUM X COPPER	NOTE	XXXXXX				
FREQUENCY IN HERTZ	50/60	BY	ENG. LOG.	TITLE	3-PHASE, 600 VOLT CLASS ISOLATION		
PRIMARY TAPS	380, 420	DATE			DRY TYPE TRANSFORMER		
- DC	A CEDITONI.	REV	MFG. LOG.	DWG. NO. 3FF774FST9			
10	O O EKTIKHIN'	DATE:	DWG. FILE				