


NOTES:

- 1. ALL UNITS ARE CUL LISTED AND DESIGNED ACCORDANCE WITH INDUSTRY STANDARDS.
- ACCORDANCE WITH INDUSTRY STANDARDS.

 2. TRANSFORMERS ARE DRY—TYPE, CLASS
 AA, ENCAPSULATED NEMA 3R ENCLOSED
- FOR INDOOR / OUTDOOR USE.

 3. TRANSFORMERS ARE WALL / MACHINE MOUNTABLE VIA THE ATTACHED BRACKETS.
- 4. TRANSFORMERS ARE CONSTRUCTED BASED UPON A 40°C AMBIENT ENVIRONMENT.
- 5. MAINTAIN 1" CLEARANCE FROM ALL LIVE PARTS.
- 6. PAINT COLOR IS ANSI #61.



APPROXIMATE DIMENSIONS (INCHES)

					`							
KVA	А	В	С	D	E	F	HARDWARE	MTG SLOTS	ENCLOSURE	lbs.	WEATHER SHIELD	TERMINAL TYPE
1.0	11.25	5.25	6.50	10.50	3.50		1/4-20	0.312" x 0.812"	FPT-500	30	N/A	LEADs

* ELECTROSTATIC SHIELD GROUNDED TO TRANSFORMER CASE AT FACTORY (IF APPLICABLE)

DRAWINGS

☑ APPROVAL

☐ RECORD

							☐ OTHER			
PRIMARY VOLTAGE	600		CUST.	xxxxxxxx	Х					
SECONDARY VOLTAGE	120 x 2	240	JOB							
TEMPERATURE RISE IN °C	115		CATALOG	CATALOG						
WINDINGS & TERMINALS	X ALUMINUM	COPPER	NOTE	ELECTROSTA	ATICALLY SHIELDED					
FREQUENCY IN HERTZ	60		BY	ENG. LOG.	TITLE					
PRIMARY TAPS	540, 57	70	DATE							
-DCD	A ŒDI	REV	MFG. LOG.	DWG. NO.	PT600-1K	-				
10	OVENI	DATE:	DWG. FILE		F1000-1K					