


## NOTES:

- ALL UNITS ARE CUL LISTED & DESIGNED ACCORDANCE WITH INDUSTRY STANDARDS.
- 2. TRANSFORMERS ARE DRY—TYPE, CLASS
  AA, HOUSED WITHIN NEMA 12 ENCLOSURE
  FOR INDOOR / DUSTPROOF USE.
- 3. DISCONNECT HAS DUAL BRACKET SYSTEM FOR BACK OR BOTTOM MOUNTING.
- 4. TRANSFORMERS ARE CONSTRUCTED BASED UPON A 40°C AMBIENT ENVIRONMENT.

**DRAWINGS** 

- 5. MAINTAIN 1" CLEARANCE FROM ALL LIVE PARTS.
- 6. PAINT COLOR IS RAL# 7042.



## APPROXIMATE DIMENSIONS ( INCHES )

KVA	А	В	O	D	E	F	HARDWARE	MTG SLOTS	ENCLOSURE	lbs.	WEATHER' SHIELD	TERMINAL TYPE
7.5	15.25	18.00	12.25	11.50	17.00	7.50	3/8-16	0.500" x 0.750"	PLDN-5K	145	N/A	TBs

X APPROVAL RECORD \* ELECTROSTATIC SHIELD GROUNDED TO TRANSFORMER CASE AT FACTORY ( IF APPLICABLE ) □ OTHER PRIMARY CUST. 480 XXXXXXX VOLTAGE SECONDARY JOB 120 VOLTAGE TEMPERATURE RISE IN °C 115 200kA SCCR FUSIBLE DISCONNECT SWITCH PRIMARY: WINDINGS & **COPPER ALUMINUM** SECONDARY: 15A DUPLEX RECEPTACLE and RED POWER-ON LIGHT TERMINALS FREQUENCY BY ENG. LOG. TITLE 1-PHASE, 600 VOLT CLASS 60 HERTZ LIGHTING DISCONNECT DATE PRIMARY DRY TYPE TRANSFORMER NONE **TAPS** MFG. LOG. DWG. NO. REV PLDN-7500-A DWG. FILE DATE: