


## NOTES:

- ALL UNITS ARE cUL LISTED & DESIGNED ACCORDANCE WITH INDUSTRY STANDARDS.
- 2. TRANSFORMERS ARE DRY-TYPE, CLASS AA, ENCAPSULATED NEMA 12 ENCLOSED FOR INDOOR / DUSTPROOF USE.
- 3. TRANSFORMERS ARE WALL / MACHINE MOUNTABLE VIA THE ATTACHED BRACKETS.
- 4. TRANSFORMERS ARE CONSTRUCTED BASED UPON A 40°C AMBIENT ENVIRONMENT.
- 5. MAINTAIN 1" CLEARANCE FROM ALL LIVE PARTS.
- 6. PAINT COLOR IS RAL# 7042.



## APPROXIMATE DIMENSIONS ( INCHES )

KVA	А	В	С	D	E	F	HARDWARE	MTG SLOTS	ENCLOSURE	lbs.	WEATHER' SHIELD	TERMINAL TYPE
15.0	15.25	15.50	11.00	8.50	14.38		3/8-16	0.437" × 0.750"	N15	200	N/A	LEADs

st ELECTROSTATIC SHIELD GROUNDED TO TRANSFORMER CASE AT FACTORY ( IF APPLICABLE )

DRAWINGS

APPROVAL

RECORD

						OTHER
PRIMARY VOLTAGE	240 x 480	CUST.	XXXXXXX			•
SECONDARY VOLTAGE	120 x 240	JOB				
TEMPERATURE RISE IN °C	115	CATALOG				
WINDINGS & TERMINALS	LALUMINUM KOPPER	NOTE	XXXXXXXX			
FREQUENCY IN HERTZ	60	BY	ENG. LOG.	TITLE	1-PHASE, 600 VOLT CLASS ISOLATION	
PRIMARY TAPS	NONE	DATE		DRY TYPE TRANSFORMER		
D.CD	A ÆDTDONI.	REV	MFG. LOG.	DWG. NO.		
12 <del>0</del> 1	<del>VVERTKAN.</del>	DATE:	DWG. FILE		NF134L15	